

## NOTICE ABOUT YOUR DRINKING WATER

### Failure to Correct a Significant Deficiency

Public Water System Name: Washington Elementary School PWS ID: 2435020

We are required to correct significant water system deficiencies identified by Department of Environmental Services (NHDES). We failed to take the required action by the established date.

**This is not an emergency.** If it had been, you would have been notified immediately. We do not know of any case of contamination. However, until the problem is corrected, there is an increased chance that disease causing organisms could contaminate the water supply and potentially cause an illness.

*Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms include bacteria, viruses and parasites which can cause symptoms such as; nausea, cramps, diarrhea and associated headaches. These symptoms, however, are not caused only by organisms in drinking water, but also by other factors. If you experience any of these symptoms and they persist, you may want to seek medical advice.*

**What should I do?** There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions.

The table below lists the outstanding significant deficiency(ies), when correction of the deficiency(ies) was due and the corrective action we have (or will be) taking.

Significant Deficiency(ies) Noted	Date(s) Correction was Due
Operation and Maintenance Inadequate (OAM) - Bulk Water Delivery Access to storage tank	5/31/2023

Steps being taken to correct the situation: The work to correctr these deficiencies is being performed  
Wednesday, 8/23/2023

Expected Resolution Date: 8/23/2023

Contact Name: Joshua Horner Company: WSO Plus, Inc.

Address: P.O Box 68 Telephone Number: 603-428-3525

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example; people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*